



ALL VALVES ARE CERTIFIED TO NSF/ANSI 372 FOR USE WITH POTABLE WATER

Model	Number of Hardwired Sensors	Valve Size	A	B	C	D	E	F	G	H	Flow GPM
WCDACTDUALHW	1	-	-	-	-	0.74	3.78	4.10	5.00	4.05	-
WCDACTDUALHW2	2										
WCDACTDUALHW	1	1/2	1/2 - 14 NPT	2.60	4.78	0.74	3.78	4.10	5.00	4.05	-
WCDACTDUALHW2	2										
WCDACTDUALHW	1	3/4	3/4 - 14 NPT	2.90	5.02	0.74	3.78	4.10	5.00	4.05	-
WCDACTDUALHW2	2										
WCDACTDUALHW	1	1	1 - 11-1/2 NPT	3.56	5.19	0.74	3.78	4.10	5.00	4.05	-
WCDACTDUALHW2	2										
WCDACTDUALHW	1	1 1/4	1-1/4 - 11-1/2 NPT	3.66	5.18	0.74	3.78	4.10	5.00	4.05	-
WCDACTDUALHW2	2										

Enclosure: Polycarbonate
 Power: Power Converter With 20' Cord
 Controls: Local Controls
 Valve: Full Port Brass Ball Valve
 Frequency: 418 MHz

UNCONTROLLED DRAWING

THIS PRINT IS THE PROPERTY OF DYNAQUIP CONTROLS AND SHALL NOT BE COPIED, REPRODUCED, LOANED, OR DISPOSED OF DIRECTLY OR INDIRECTLY, NOR USED FOR ANY PURPOSE OTHER THAN THAT FOR WHICH IT IS SPECIFICALLY FURNISHED EXCEPT BY WRITTEN PERMISSION OF DYNAQUIP CONTROLS.

NO. **WCDACTDUALHW** FILE NO. SUB407

TITLE
Actuator shown with valve attached

DR	DATE	CHKD	DATE	ENGR	DATE
MJP	07-17-19	CMM	12-19-17	CMM	12-19-17

