



**ALL VALVES ARE CERTIFIED TO NSF/ANSI 372 FOR USE WITH POTABLE WATER**

Model	Cable Length
ZWK25W	25'
ZWK50W	50'
ZWK75W	75'

Valve Size	A	B	C	Flow GPM
1/2	1/2 - 14 NPT	2.60	4.72	19
3/4	3/4 - 14 NPT	2.90	5.02	34
1	1 - 11-1/2 NPT	3.56	5.17	52
1 1/4	1-1/4 - 11-1/2 NPT	4.09	5.44	77

**UNCONTROLLED DRAWING**

THIS PRINT IS THE PROPERTY OF DYNAQUIP CONTROLS AND SHALL NOT BE COPIED, REPRODUCED, LOANED, OR DISPOSED OF DIRECTLY OR INDIRECTLY, NOR USED FOR ANY PURPOSE OTHER THAN THAT FOR WHICH IT IS SPECIFICALLY FURNISHED EXCEPT BY WRITTEN PERMISSION OF DYNAQUIP CONTROLS.

NO. **Z-Wave** FILE NO. **Sub324**

TITLE **Z-Wave Below Grade Actuator**

DR	DATE	CHKD	DATE	ENGR	DATE
MJP	07-25-18	MWS	11-12-15	MWS	11-12-15

