



Dry Contact Closure  
In Alarm Condition  
COM 1 & N.O. 1

Dry Contact Closure  
In Alarm Condition  
COM 2 & N.O. 2

ALL VALVES ARE CERTIFIED  
TO NSF/ANSI 372 FOR USE  
WITH POTABLE WATER

Model	Valve Size	A	B	C	D	E	F	Ends
WCLSLFA 1/2	1/2	5.00	3.75	4.72	.74	3.25	2.60	1/2 - 14 NPT
WCLSLFA 3/4	3/4	5.00	3.75	5.02	.74	3.25	2.90	3/4 - 14 NPT
WCLSLFA 1	1	5.00	3.75	5.17	.74	3.25	3.56	1 - 11-1/2 NPT
WCLSLFA 1-1/4	1 1/4	5.00	3.75	5.44	.74	3.25	3.66	1-1/4 - 11-1/2 NPT

**UNCONTROLLED DRAWING**

THIS PRINT IS THE PROPERTY OF DYNAQUIP CONTROLS AND SHALL NOT BE COPIED, REPRODUCED, LOANED, OR DISPOSED OF DIRECTLY OR INDIRECTLY, NOR USED FOR ANY PURPOSE OTHER THAN THAT FOR WHICH IT IS SPECIFICALLY FURNISHED EXCEPT BY WRITTEN PERMISSION OF DYNAQUIP CONTROLS.

NO.		Leak Stop Plus				FILE NO.
		Valve Actuator				SUB. 283
DR	DATE	CHKD	DATE	ENGR	DATE	
mjp	04-10-18	MWS	10-10-16	MWS	10-10-16	